

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 12/05/2025/01 Dated: 12.05.2025
It is certified that an inspection team headed by Raj Kisor Tyagi & Hema Soni
(Name of Officers with designation) from C. H. C. Narhi PHED
inspected the Raj Gurukul Vidhyapeeth, Kathahi Kripalpur
Maldi, Ballia U.P.
(Name & Address of the school) on 12/05/25 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. WAR/BAL/149/2025-26 dated 09-06-25
of District Level Water Analysis Jal Nigam (Kural) Lab Ballia
(PHED Lab) certified that
the Raj Gurukul Vidhyapeeth (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.
This certificate is valid till One year (01)
Signature with Seal: C. H. C. Narhi
Name : Ballia (U.P.)
Designation :
Name & Address of the Office / Department :
To The Manager
Raj Gurukul Vidhyapeeth
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Analysis Laboratory

U.P Jal Nigam (Rural), Opposite SMTD College, Ballia. Pin- 277001

Rept No	149	Date	09/06/2025	Page No	01
Customer Details					
Office Name and Address	RAJ GURUKUL VIDYAPEETH, Kathahi, Kripalpur, Haldi, Ballia, U.P.				
Ref Letter No.	WAR/BAL/149/2025-26				
Basic details of sample					
District	Ballia	Tehsil	Ballia		
Gram Panchayat	Kathahi, Kripalpur	Village	Kathahi		
Habitation	-	Location	Kathahi, Kripalpur, Haldi, Ballia, U.P.		
Water Source	R O Water	Sample No.	Sample 5		
Quality of Sample	1000ml (Normal)	Date of S.C.	09/06/2025		
Receiving Date	09/06/2025	S. Collector	Mr. Rahul Kumar		
Sample Depositor	Mr. Mrityunjay Tiwari				
Analysis Start Date	09/06/2025	Analysis Completion Date	09/06/2025		
Technical Data of Analysis					
SR	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	5.45	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 1983:2021(Electrometric Method)
2	Turbidity (NTU)	0.55	1.00	5.00	IS 3025 (Part 10): 1984:2021(Nephelometer Method)
3	TDS. Mg/1	310	500	2000	IS 3025 (Part 16): 1984:2021(Gravimetric Method)
4	Chloride (as Cl), mg/1	09	250	1000	IS 3025 (Part 32): 1988:2021(Titration Method)
5	Total Alkalinity (as Na ₂ CO ₃), mg/1	184	200	600	IS 3025 (Part 23): 1986:2021(Titration Method)
6	Total Hardness (as CaCO ₃), mg/1	97	200	600	IS 3025 (Part 21): 2009:2021(Titration Method)
7	Calcium (as Ca), mg/1	17.9	75	200	IS 3025 (Part 40): 2019
8	Magnesium (as Mg), mg/1	16.6	30	100	IS 3025 (Part 46): 2019
9	Nitrate (as NO ₃), mg/1	6	45	No Relaxation	APHA 23rd Ed 2017, 4500-NO ₃ (B.Ultraviolet Spectrophotometric Screening Method)
10	Fluoride (as F), mg/1	0.330	1.00	1.5	APHA 23rd Ed 2017, 4500-F (C. Ion Selection Electrode Method)
11	Iron (as Fe), mg/1	1.00	1.00	No Relaxation	APHA 23rd Fd 2017, 3500-Fe (B Phenanthroline Method)
12	Residual Chlorine	0.2	NA	0.2	IS 3025 (Part 26): 2021
13	Total Coliform (MPN/100mL)	0	NA	0.0	IS 1622
Note:-					
1. This Certificate refers only to the particular sample(s) submitted for testing.					
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.					
3. The test result reported in this certificate is valid at the time of and under the stated conditions of measurements.					
4. Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.					


Prepare by

Lab Technician


Authorized Signatory

Quality/Technical Manager